

ELDAŞ is ACCREDITED by  
TURKISH ACCREDITATION AGENCY



Test  
TS EN ISO/IEC 17025  
AB-0045-T

AB-0045-T

EL-1601/R1

08-12



**ELDAŞ**  
Elektrik Elektronik Sanayi ve Tic.A.Ş.

1.Organize Sanayi Bölgesi Büyük Selçuklu Bulvarı No:2/A  
Sincan 06935 - ANKARA /TURKEY

## TESTING REPORT

Customer name/address : Mikroelektronika AD  
Blagoja Parovića bb - Novakovići 78000 Banja Luka Bosnia and Herzegovina

Order No: 120701-10

Name and identity of test item: Mikroelektronika Single Phase Multifunctional Electricity Meter  
Type MEM500, 1Phase-2 Wire, with S-FSK PLC Modem

The date of receipt of test item: 01.07.2012

Remarks: 0,25-5(80) A, 230 V, 50Hz, Class B, 1000 Imp/kWh, 3K7

Date of test: 23.07.2012 - 15.08.2012

Number of pages of the Report: 28

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

This report was prepared after applying test/tests to the samples that are sent to our company.  
(Note that this report does not involve other samples of the customer.)

Seal and Date

Person in Charge of Test

Head of testing laboratory



  
Ahmet CANBOLAT

  
Ahmet ÖZCAN

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

## Testing Report

Page: 2/28

### CONTENTS

	Page No:
<b>Contents:</b>	2
<b>Test Standards:</b>	3
<b>List of Test Equipment:</b>	4
<b>Short Description of EUT:</b>	5
<b>Ambient Temperature Variation</b>	6
<b>Power Consumption Testing</b>	7
<b>Influence of Short-Time Overcurrents</b>	8
<b>Heating Testing</b>	9
<b>Insulation Testing</b>	10
<b>Protection against penetration of dust and water</b>	11
<b>Immunity to Power Frequency Magnetic Fields of External Origin</b>	12
<b>Voltage Dips and Short Interruptions</b>	13
<b>Magnetic Induction of External Origin</b>	14
<b>Electrical Fast Transient / Burst Immunity Test</b>	15
<b>Radiated, Radio Frequency, Electromagnetic Field Immunity Test</b>	16-20
<b>Immunity to Conducted Disturbances, Induced by Radio Frequency Fields</b>	21
<b>Electrostatic Discharge Immunity Test</b>	22-23
<b>Surge Immunity Test</b>	24
<b>Photos of EUT</b>	25-28

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

## Testing Report

Page: 3/28

### TEST STANDARDS

The tests were performed according to following standards

- EN 50470-1:2006
- EN 50470-3:2006

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 4/28

**List of Test Equipment****The tests were performed using following test equipment.**

Device/Equipment Name)	Brand	Serial No
■ Termohygrometer	OMKA	THG-05
■ Dust room	MATEŞ	
■ Rain test device	EMS	ST-2003
■ Reference watt-hour meter	Zera	D-53639
■ Cooled incubator	NÜVE	02-0261
■ 400 A turned bobbin	Mateş	-----
■ 1000 A turned bobbin	Mateş	-----
■ Combined Test Device	CT-2003	2003-04
■ Deepfreezer	DAIREI	6070011
■ Best EMC	Schaffner	200222-074SC
■ E Stacked Double Log-Per.Antenna	Schwarzbeck	9128E 006
■ Solid State Power Amplifier 15W	Bonn Elektronik	035357A
■ Trilog-Broadband Antenna	Schwarzbeck	9168-142
■ N-Dämpfungsglied 10dB DC-1GHz	Schwarzbeck	9234
■ Coupling Decoupling	EMC Elektronik Ltd.	2312040019
■ Termo Hygrometre	--	THG-01
■ Power Amplifier 55W	Milmega	991944
■ Solid State Power Amplifier 50W	Bonn Elektronik	035357B
■ Video Monitors	Philips	M2030409
■ Midi Camera	Samsung	.....
■ Emi Test Reciever	Rohde & Schwarz	100173
■ Signal Generator	Rohde & Schwarz	100845
■ E Field Probe	Ets-Lindgen	90405
■ Lisn	EMC Elektronik	0812040601
■ Ultra Compact Simulator	EM Test	V0630101686
■ ESD Simulator	EM Test	V0630101687

**This report shall not be reproduced other than in full except with the permission of the laboratory.**  
**Testing reports without signature and seal are not valid.**

## Testing Report

Page: 5/28

### Short Description of EUT

Trademark	: MIKROELEKTRONIKA
Type	: MEM500
Basic Voltage	: 230 V
Minumum Current	: 0,25 A
Transitional Current	: 0,5 A
Reference Current	: 5 A
Maximum Current	: 80 A
Meter Constant	: 1000 imp/kWh
Class (EN 50470-1/3)	: B
Phase/Wire Number	: 1 Phase/ 2 wire
Tariff	: Multi Tariff
Reference frequency	: 50 Hz
In Door (IP 51)/Out Door (IP 54)	: Out Door (IP 54)
Specified Operating range	: 3K7
Communication Port	: Optical Interface (IR), Electrical Interface (RS-485), S-FSK PLC Modem

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

## Testing Report

Page: 6/28

**Test Name:**Ambient Temperature Variation

**EUT:** MEM500 (120701-10/01)

**Environmental Conditions:** 23 °C % 42 RH

**Date:** 23.07.2012 - 24.07.2012

**Test Method Num:** DT-EL-05

**Applicable Standards:**EN 50470-3 Article 8.3 , Table-6

Temperature Variation	Value of Current	Max measured additional error for each Power Factor			Limits of Additional Percentage Error for Class B	
		Cos f=1	Cos f=0,5	Cos f=0,8cap	Cos f=1	Cos f=0,5ind-08cap.
-40°C	I <sub>min</sub> = 0,25A	0,33	--	--	±3,1	--
	I <sub>tr</sub> = 0,5A	0,30	0,22	0,25	±3,1	±4,4
	I <sub>ref</sub> = 5A	0,33	0,37	0,37	±3,1	±4,4
	I <sub>max</sub> = 80A	0,33	0,31	0,26	±3,1	±4,4
-25°C	I <sub>min</sub> = 0,25A	0,24	--	--	±2,4	--
	I <sub>tr</sub> = 0,5A	0,24	0,21	0,21	±2,4	±3,4
	I <sub>ref</sub> = 5A	0,21	0,24	0,31	±2,4	±3,4
	I <sub>max</sub> = 80A	0,23	0,22	0,24	±2,4	±3,4
-10°C	I <sub>min</sub> = 0,25A	0,14	--	--	±1,6	--
	I <sub>tr</sub> = 0,5A	0,11	0,13	0,16	±1,6	±2,3
	I <sub>ref</sub> = 5A	0,14	0,11	0,14	±1,6	±2,3
	I <sub>max</sub> = 80A	0,12	0,14	0,18	±1,6	±2,3
5°C	I <sub>min</sub> = 0,25A	0,02	--	--	±0,9	--
	I <sub>tr</sub> = 0,5A	0,03	0,05	0,02	±0,9	±1,3
	I <sub>ref</sub> = 5A	0,04	0,03	0,03	±0,9	±1,3
	I <sub>max</sub> = 80A	0,02	0,02	0,04	±0,9	±1,3
30°C	I <sub>min</sub> = 0,25A	0,06	--	--	±0,9	--
	I <sub>tr</sub> = 0,5A	0,08	0,06	0,06	±0,9	±1,3
	I <sub>ref</sub> = 5A	0,07	0,03	0,04	±0,9	±1,3
	I <sub>max</sub> = 80A	0,04	0,03	0,08	±0,9	±1,3
40°C	I <sub>min</sub> = 0,25A	0,14	--	--	±1,6	--
	I <sub>tr</sub> = 0,5A	0,12	0,13	0,11	±1,6	±2,3
	I <sub>ref</sub> = 5A	0,11	0,12	0,16	±1,6	±2,3
	I <sub>max</sub> = 80A	0,16	0,14	0,14	±1,6	±2,3
55°C	I <sub>min</sub> = 0,25A	0,22	--	--	±2,4	--
	I <sub>tr</sub> = 0,5A	0,26	0,27	0,24	±2,4	±3,4
	I <sub>ref</sub> = 5A	0,24	0,26	0,21	±2,4	±3,4
	I <sub>max</sub> = 80A	0,28	0,21	0,22	±2,4	±3,4
70°C	I <sub>min</sub> = 0,25A	0,30	--	--	±3,1	--
	I <sub>tr</sub> = 0,5A	0,33	0,29	0,26	±3,1	±4,4
	I <sub>ref</sub> = 5A	0,33	0,37	0,43	±3,1	±4,4
	I <sub>max</sub> = 80A	0,38	0,35	0,37	±3,1	±4,4

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 7/28

**Test Name:Power Consumption Testing****EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 22 °C % 42 RH**Date:** 25.07.2012**Test Method Num:** DT-EL-10**Applicable Standards:** EN 50470-3 Article 7.1 - EN 62053-61 Article 4.3.1 Table 1

- The active and apparent power loss in each voltage circuit of a meter at reference voltage, reference temperature and reference frequency shall not exceed the values shown in table.

Power Consumption in each Voltage Circuit	Max.Power Consumption in each Voltage Circuit Given in 4.3.1
R : 4,96 W / 4,96 VA S : W T : W	5 W and 25 VA

$$R: 1 * 21,6 \text{ mA} * 230 \text{ V} = 4,96 \text{ W}$$

$$R: 21,6 \text{ mA} * 230 \text{ V} = 4,96 \text{ VA}$$

- The apparent power taken by each current circuit of a meter at reference current, reference frequency and reference temperature shall not exceed the values shown in table.

Power Consumption in Current Circuits	Max.Power Consumption in current Circuit Given in 7.1.3
R : 0,041 VA S : VA T : VA	4,0 VA

$$R: 8,2 \text{ mV} * 5 \text{ A} = 0,041 \text{ VA}$$

**Result : Positive**

**This report shall not be reproduced other than in full except with the permission of the laboratory.**  
**Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 8/28

**Test Name:**Influence of Short-Time Overcurrents**EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 22 °C % 42 RH**Date:** 26.07.2012**Test Method Num:** DT-EL-06**Applicable Standards:**EN 50470-3 Article 8.6

Value of Current	Cos f	Error Difference (%) between ;before Overcurrents and after Overcurrents.	Max.Error Difference , Given in Article 8.6
(10 I <sub>tr</sub> )	1	0,04	1,5

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.



## Testing Report

Page: 9/28

**Test Name:**Heating Testing**EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 23 °C % 42 RH**Date:** 27.07.2012**Test Method Num:** DT-EL-08**Applicable Standards:**EN 50470-1 Article 7.2

While the ambient temperature is 40°C the meter rated max. current and 1,15 times the reference voltage, tested.The duration of the test is two( 2) hours. The temperature rise of the external surface shall not exceed 25 K.

Position of the sensor at the terminal block	Back side near terminals	Back side in the middle
Temperature at the start (°C)	+40	+40
Temperature after 2 hours (°C)	+53	+49
Variation (°C)	+13	+9

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 10/28

**Test Name:Insulation Testing****EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 22 °C % 42 RH**Date:** 30.07.2012**Test Method Num:** DT-EL-15**Applicable Standards:**EN 50470-1 Article 7.3.3, EN 50470-1 Article:7.3.4**a) Impulse Voltage Tests for Circuits and between the Circuits : (Article 7.3.3.2)**

Impulse Waveform :1,2/50 impulse specified in IEC 60060-1

Voltage Rise Time:  $\pm 30\%$ Voltage Fall Time :  $\pm 20 \%$ Source Impedance : (  $500 \Omega \pm 50 \Omega$  )Source Energy : (  $0,5 \text{ J} \pm 0,05 \text{ J}$  )

Test Voltage: In accordance with Table 3a or 3b 6 kV

Test Voltage Tolerance:  $\begin{matrix} +0 \\ -10 \end{matrix} \%$ 

For each test , the impulse voltage is applied ten times with one polarity and then repeated with the other polarity .The minumum time between the impulses shall be 3 s.

After the test ;the meter shall show no damage and shall operate correctly.

After the test the percentage errors shall not exceed the limits given in Table-6

**Remark: Test was applied to current and voltage circuits according to EN 50470-1 Article 7.3.3.2****Result: Positive****b) Impulse Voltage Test of Electric Circuits Relative to Earth: (Article 7.3.3.3)**

The impulse voltage applied between all the electric circuits and earth.

Duringthe test no flashover, disruptive, discharge or puncture shall occur.

**Remark: Test was applied to current and voltage circuits according to EN 50470-1 Article 7.3.3.3****Result: Positive****c) A.C Voltage Test: (EN 50470-1 Article:7.3.4)**

The test voltage shall be 4kV and applied for 1 minute between parts of the meter which given in Table -5. During the test no flashover, disruptive discharge or puncture shall occur.

**Remark: Test was applied to current and voltage circuits, auxiliary circuits was connected to earth.****Result: Positive****Result: Positive****This report shall not be reproduced other than in full except with the permission of the laboratory.****Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 11/28

**Test Name:Protection against penetration of dust and water****EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 23 °C % 41 RH**Date:** 01.08.2012 - 02.08.2012**Test Method Num:** DT-EL-36**Applicable Standards:**EN 50470-1 Article 5.9

Degree of protection = Outdoor meter (IP54)

The EUT tested according to IEC 60529, under the following conditions.

- Meter in-non operating condition and mounted on a artificial wall.
- Any ingress of dust and water shall be only in a quantity not impairing the operation of the meter.
- After this test a insulation test is applied.

Error (%) before the test

Reference Current (5)A	ACTIVE			REACTIVE	
	cosf=1	cosf=0,5ind.	cosf=0,8cap.	sinf=1	sinf=-1
	-0,10	-0,27	-0,10	--	--

Error (%) after the test

Reference Current (5)A	ACTIVE			REACTIVE	
	cosf=1	cosf=0,5ind.	cosf=0,8cap.	sinf=1	sinf=-1
	-0,11	-0,26	-0,10	--	--

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 12/28

**Test Name:**Immunity to Power Frequency Magnetic Fields of External Origin**EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 22 °C % 40 RH**Date:** 04.08.2012**Test Method Num:** DT-EL-13**Applicable Standards:**EN 50470-3 Article 8.5 , Table-9 ,EN 50470-1 Article 7.4.12

Current Value	Error Difference between Magnetic Induction of 0,5mT and Normal Conditions	Max.Error Difference Given in Article 8.5
10 ltr	0,04	2,0

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 13/28

**Test Name: Voltage Dips and Short Interruptions****EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 21 °C % 41 RH**Date:** 04.08.2012**Test Method Num:** DT-EL-18**Applicable Standards:** EN 50470-1 Article 7.4.4

$$m = 1$$

$$U_n = 230 \text{ V}$$

$$I_{\max} = 80 \text{ A}$$

$$X = 10^{-6} \cdot m \cdot U_n \cdot I_{\max} = 0,0184 \text{ kWh}$$

Voltage Interruptions	Change in the Register (kWh)	Max.Change in the Register (kWh), Given in Article 7.4.4
$\Delta U = \%100$ , $Dt = 1 \text{ s}$	0	0,0184
$\Delta U = \%100$ , $Dt = 20 \text{ ms}$	0	0,0184
$\Delta U = \%50$ , 1 minute.	0	0,0184

**Result : Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 14/28

**Test Name:**Immunity to Continuous Magnetic Fields of External Origin**EUT:** MEM500 (120701-10/01)**Environmental Conditions:** 22 °C % 42 RH**Date:** 04.08.2012**Test Method Num:** DT-EL-14**Applicable Standards:**EN 50470-3 Article 8.5 , Table-9, EN 50470-1 Article 7.4.11

Current Value	Error Difference between Continuous Magnetic Induction and Normal Conditions	Max.Error Difference Given in Article 8.5
10 ltr	0,03	2,0

**Result : Positive****This report shall not be reproduced other than in full except with the permission of the laboratory.****Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 15/28

**Electrical Fast Transient / Burst Immunity Test**

Test Method No	DT-EMC-06	Related Standard:	IEC 61000-4-4:2004 EN 50470-1
Environmental Cond.:	21°C, % 41 RH	Date:	15.08.2012

**TEST CONDITIONS AND RESULTS**

**Testin tanımı:**  
(Test specification)

EUT has been placed on a nonconducted table 10 cm height from reference earth plane in shielded room. EuT has been supplied with 230 voltage and 5 Ampere. Burst signal is applied to L,N couplings and error difference measured.

<b>Test level:</b>	<input type="checkbox"/> 0.5 kV (Level 1)	<input type="checkbox"/> 1 kV (Level 2)
	<input type="checkbox"/> 2 kV (Level 3)	<input checked="" type="checkbox"/> 4 kV (Level 4)
<b>Burst frequency :</b>	<input checked="" type="checkbox"/> 5,0 kHz	<input type="checkbox"/> 2,5 kHz
<b>Coupling time :</b>	<input checked="" type="checkbox"/> - - $\geq 60$ s	
<b>Polarity :</b>	<input checked="" type="checkbox"/> Positive	<input checked="" type="checkbox"/> Negative

Max. Error Difference (%) is % 4 according to EN 50470-3 article 8.5  
Measured Max. Error Difference (%) is: 0,66

**Result: Positive**

**This report shall not be reproduced other than in full except with the permission of the laboratory.**  
**Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 16/28

# Radiated, Radio Frequency, Electromagnetic Field Immunity Test

Test Method No: DT-EMC-05 Related Standard: IEC 61000-4-3:2006  
EN 50470-1  
Environmental Cond.: 21°C, % 41 RH Date: 14.08.2012

**TEST CONDITIONS AND RESULTS**

Test specification: EUT has been supplied with 230 voltage in Anechoic Chamber on a wooden table that is above 80 cm height from floor. When 5 A has been applied to current circuit and without any current test has been made. In the horizontal and vertical positions of the antenna, test is made by turning EUT four dimensions.

Frequency range : ☒ 80 MHz – 1000 MHz ☒ 1000 MHz – 2000 MHz

☐ 27 MHz – 500 MHz

Field strength : ☐ 3 V/m ☒ 10 V/m ☒ 30 V/m  
With current Without current

Distance of antenna – EuT: ☒ 1 m ☒ 3 m ☐ 10 m  
Without current With current

**Result: Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.



**Testing Report**

Page: 17/28

# Radiated, Radio Frequency, Electromagnetic Field Immunity Test

**Modulation :** ■ AM 80% (Amplitude)  
■ Sinusoidal 1kHz

**Frequency step :** ■ 1 % with 2 s dwell time

**Polarization of antenna :** ■ Horizontal ■ Vertical

<b>Mode:</b>	Without load	Without load
<b>Side:</b>	Front	Front
<b>Polarization:</b>	Horizontal	Vertical
<b>Deviation(x):</b>	0 Wh	0 Wh

<b>Mode:</b>	Without load	Without load
<b>Side:</b>	Back	Back
<b>Polarization:</b>	Horizontal	Vertical
<b>Deviation(x):</b>	0 Wh	0 Wh

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 18/28

## Radiated, Radio Frequency, Electromagnetic Field Immunity Test

<b>Mode:</b>	Without load	Without load
<b>Side:</b>	Right	Right
<b>Polarization:</b>	Horizontal	Vertical
<b>Deviation(x):</b>	0 Wh	0 Wh

<b>Mode:</b>	Without load	Without load
<b>Side:</b>	Left	Left
<b>Polarization:</b>	Horizontal	Vertical
<b>Deviation(x):</b>	0 Wh	0 Wh

The application of the immunity test shall not produce a change in the register of more than x units and the test output shall not produce a signal equivalent to more than x units.

$x=10^{-6} \cdot m \cdot U_n \cdot I_{max} = kWh$        $m$       is the number of measuring elements

$U_n$       is the reference voltage

$I_{max}$       is the maximum current

$x=0,0184 kWh$

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 19/28

# Radiated, Radio Frequency, Electromagnetic Field Immunity Test

**Modulation :** ■ AM 80% (Amplitude)  
■ Sinüs(sinusoidal) 1kHz

**Frequency step :** ■ (1 % with 2 s dwell time)

**Polarization of antenna :** ■ Horizontal ■ Vertical

<b>Mode:</b>	(With Current, 5 Ampere)	(With Current, 5 Ampere)
<b>Side:</b>	Front	Front
<b>Polarization:</b>	Horizontal	Vertical
<b>Max. Error Difference:</b>	1,11%	0,87%

<b>Mode:</b>	(With Current, 5 Ampere)	(With Current, 5 Ampere)
<b>Side:</b>	Back	Back
<b>Polarization:</b>	Horizontal	Vertical
<b>Max. Error Difference:</b>	1,07%	1,00%

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 20/28

# Radiated, Radio Frequency, Electromagnetic Field Immunity Test

**Mode:** (With Current, 5 Ampere) (With Current, 5 Ampere)

**Side:** Right Right

**Polarization:** Horizontal Vertical

**Max. Error Difference:** 0,98% 1,03%

**Mode:** (With Current, 5 Ampere) (With Current, 5 Ampere)

**Side:** Left Left

**Polarization:** Horizontal Vertical

**Max. Error Difference:** 0,18% 0,85%

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 21/28

# Immunity to Conducted Disturbances, Induced by Radio Frequency Fields

Test Method No:	DT-EMC-09	Related Standard:	IEC 61000-4-6:2006 EN 50470-1
Environmental Cond.:	22°C, % 42 RH	Date:	14.08.2012

**TEST CONDITIONS AND RESULTS**

**Test specification :** The supply peaks of the EUT is connected to CDN. When the devices has been applied with 230V, When 5A has been applied to current circuits, Eut has been observed.

Frequency range : ■ 0,15 MHz – 80 MHz

Field strength : □ 3 V ■ 10 V

Modulation : ■ AM 80% Amplitude  
■ Sinusoidal 1kHz

Frequency step : ■ 1 % with 2 s dwell time

Max. Error Difference (%) is % 2 according to EN 50470-3 article 8.5

Measured Max. Error Difference (%) is: 0,18

**Result:Positive**

**This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 22/28

**Electrostatic Discharge Immunity Test**

Test Method No: DT-EMC-01 Related Standard: IEC 61000-4-2:2001  
EN 50470-1  
Environmental Cond.: 21°C, % 41 RH Date: 15.08.2012

**TEST CONDITIONS AND RESULTS**

**Test specification:** EUT has been placed on a wooden table 80 cm height from floor in control room. When EUT is power on, contact discharge has been applied to the conductive surfaces and to vertical and horizontal coupling plates, air discharge has been applied to nonconducted surfaces.

**Contact discharge voltage :** ■ - 2kV ■ - 6 kV  
■ - 4 kV ■ - 8 kV

**Air discharge voltage:** ■ - 2 kV ■ - 8 kV  
■ - 4 kV ■ - 15 kV

**Discharge impedance :** ■ - 330  $\Omega$  / 150 pF

**Discharge factor :** ■ -  $\geq 1$  s

**Number of discharge :** ■ -  $\geq 10$

**Result: Positive**

This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 23/28

**Electrostatic Discharge Immunity Test**

Type of discharge :

- |                       |                     |
|-----------------------|---------------------|
| ■ Direct discharge:   | ■ Contact discharge |
|                       | ■ Air discharge     |
| ■ Indirect discharge: | ■ Contact discharge |

Polarity:

- Positive                      ■ Negative

Discharge location:

- Horizontal coupling plate -HCP-
- Vertical coupling plate -VCP-

The application of the electrostatic discharge shall not produce a change in the register of more than x units and the test output shall not produce a signal equivalent to more than x units.

$x=10^{-6} \cdot m \cdot U_n \cdot I_{max} = kWh$                       m                      (is the number of measuring elements)

$U_n$                       (is the reference voltage)

$I_{max}$                       (is the maximum current)

The electrostatic discharge application doesn't produce a change in the register and signal output.

**x=0,0184 kWh**

**This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.**

**Testing Report**

Page: 24/28

**Surge Immunity Test**

Test Method No: DT-EMC-03 Related Standard: IEC 61000-4-5:2005  
EN 50470-1  
Environmental Cond.: 21°C, % 42 RH Date: 15.08.2012

**TEST CONDITIONS AND RESULTS**

**Test specification:** EUT has been placed on a wooden table 80 cm height from floor in control room.  
When Eut is power on ,surge signal has been applied to Line - Line couplings.

**Test level :** ☐ 0.5 kV ☐ 1 kV  
☐ 2 kV ☒ 4 kV  
**Output:** ☒ 2 ohm Source impedance ☐ 12 ohm Ground impedance

**Phase Angle:** 60°, 240°

**Application number :** Repetition rate 1 minute

**Polarity :** Positive Negative

The application of the electrostatic discharge shall not produce a change in the register of more than x units and the test output shall not produce a signal equivalent to more than x units.

**Result:Positive**


This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.



**Testing Report**

Page: 25/28

**PRODUCT PICTURE**



This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 26/28

**PRODUCT PICTURE**



This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 27/28

**PRODUCT PICTURE**



This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.

**Testing Report**

Page: 28/28

**PRODUCT PICTURE**



This report shall not be reproduced other than in full except with the permission of the laboratory.  
Testing reports without signature and seal are not valid.